



## **Long Point Region Conservation Authority**

4 Elm St., Tillsonburg ON N4G 0C4 Tel: (519)-842-4242 Fax: (519)-842-7123  
Email: [conservation@lprca.on.ca](mailto:conservation@lprca.on.ca) Website: [www.lprca.on.ca](http://www.lprca.on.ca)

### **NOTICE OF BID / TENDER AND SPECIFICATIONS**

The Long Point Region Conservation Authority is accepting bids/quotations/tenders for the following:

#### **Required at Backus Heritage Conservation Area “22 Posts Equipped to Service 23 Campsites with Electrical Hookup”**

1. Please quote on the following:
  - 21 posts to be equipped with 1 waterproof box complete with 30-amp/120V receptacle and 1 30-amp breaker switch. Box to be mounted four feet about ground line.
  - 1 post to be equipped with 1 waterproof box complete with 2 30-amp/120V receptacles and 2 30-amp breaker switches. Box to be mounted four feet above ground line
  - 1 600-amp 120/240 single phase main service with transformer vault
  - 3 200-amp 120/240 subservices with panel enclosure
  - Re-connection of pool building and block washroom from main service underground
  - Primary dip from HydroOne pole by dump station to the transformer vault in the vicinity of site #77
  - All electrical lines to be new and supplied by the Contractor
  - All electrical lines to be buried to a minimum depth of 3 feet
  - Successful Contractor to take out the current HydroOne layout and LPRCA to absorb hydro fees
  - Electrical permits and inspections to be the responsibility of the contractor, including ESA permit and plan approvals
  - Completion date of this project to be no later than March 28, 2017
  - These new campsite services will replace existing services which provide 15-amp receptacles to all of the sites
  - All trenching and backfilling will be done by the LPRCA
  - Measurements appearing on the enclosed drawing are estimates only
  - The successful bidder must provide proof of liability insurance in the amount of \$2,000,000 (Two Million Dollars)
  - The successful bidder must provide proof of WSIB coverage
  - The successful bidder must sign a Hold Harmless Agreement





2. All applicable taxes are to be shown and included in the submitted bid/quotation/tender
3. Sealed, written bids/quotations/tenders only will be accepted until **4:00pm, Friday, January 19, 2018.**
4. Envelope should be addressed to :  
**Long Point Region Conservation Authority**  
**Attention: Judy Maxwell, Interim General Manager**  
**4 Elm St., Tillsonburg ON N4G 0C4**  
Marked **“CONFIDENTIAL”**  
**“Backus 2018 Hydro Project”**
5. The lowest or any bid/quotation/tender will not necessarily be accepted.
6. All bids/quotations/tenders received before the deadline shall be opened on **Friday, January 19, 2018 at 4:05pm** at the Authority's Administration Office in Tillsonburg. Any supplier/contractor may request the names of all bidders and the dollar value of all submitted bids/quotations/tenders.
7. The submitted bid/quotation/tender shall state that the quoted price shall be valid for at least thirty (30) days unless otherwise specified above.

Contact Frank Scram, Workshop Supervisor at 519-429-0363 if further information is required.



# Legend

1: 1,500

-  Under ground primary in duct to padmount vault location, plus grounding
-  Transformer vault and 600 AMP main service location
-  200 AMP sub-service
-  Single 30 AMP/120 V recep

